



HEATSHIELDING LIMITED



BS EN ISO 9001:2008
Certificate No 05104

WIND LOADING FOR HEAT SHIELD PANELS

Wind Force to be applied are calculated in accordance with API Recommended Practice 2A-WSD

$$F = \rho/2 \times C_s \times A \times U^2(z \ t)$$

With

- F force expressed in N
- ρ mass density of air (1.226 Kg.m³)
- C_s shield coefficient (1)
- A wind surface in m² (Effective Area of Heat Shielding)
- U(z,t) 1 min mean wind speed expressed in m.s⁻¹ at the considered elevation.

Wind Load Calculation taken at centre of Heatshield Panel at Elevation 54.22m

$$U(z,t) \text{ at cog} = U(z) \times [1 - 0.41 \times I_u(z) \times \ln(t/t_0)]$$

Where

$$t_0 = 3600 \text{ sec.}$$

$$U_z = U_0 \times [1 + C \times \ln(z/10)]$$

$$U_0 = 45.3 \text{ m.s}^{-1}$$

$$C = 5.73 \times 10^{-2} \times (1 + 0.0457 \times U_0)^{1/2}$$

$$C = 5.73 \times 10^{-2} \times (1 + 0.0457 \times 45.3)^{1/2} \\ = 0.1$$

$$\text{Therefore } U_z = 45.3 \times [1 + 0.1 \ln 5.422] \\ = 52.95 \text{ m.s}^{-1}$$

I_u(z) Turbulence intensity at elevation 54.22m

$$I_u(z) = 0.06 \times [1 + 0.0131 \times U_0] \times (z/10)^{-0.22} \\ = 0.06 \times [1 + 0.0131 \times 45.3] \times (5.422)^{-0.22} \\ = 0.066$$

$$\text{Therefore } U_{zt} = 52.95 \times [1 - 0.41 \times 0.066 \times \ln 60/3600] \\ = 58.82 \text{ m.s}^{-1}$$

A Locker Group Company



HEATSHIELDING LIMITED



BS EN ISO 9001:2008
Certificate No 05104

Effective Area of Wind Shield = 5.26m²

(Assuming all wind shielding is at 90° to applied wind force)

$$\begin{aligned} \text{Wind Force } F &= 1.226 / 2 \times 1 \times 5.26 \times 58.82^2 \\ &= 11.156 \text{ kN} \end{aligned}$$

Wind Loading / m² = 2.12 kN/m²

A Locker Group Company